



dati tecnici


plate verticale singolo

Ref.	A	B	C	White & Colors		Peso	Cap.	
				$\Delta t=50^{\circ}\text{C}$	$\Delta t=30^{\circ}\text{C}$			
				W	W			
1500 altezza height hauteur altura	PLIV150038	1505	380	1450	548	286	18,7	4,5
	PLIV150052	1505	528	1450	767	399	26,1	6,3
	PLIV150067	1505	676	1450	987	511	33,6	8,0
1800 altezza height hauteur altura	PLIV180038	1805	380	1750	650	340	21,5	5,3
	PLIV180052	1805	528	1750	910	473	30,0	7,4
	PLIV180067	1805	676	1750	1170	605	38,5	9,5
2000 altezza height hauteur altura	PLIV200038	2005	380	1950	715	374	23,5	5,8
	PLIV200052	2005	528	1950	1001	521	32,8	8,1
	PLIV200067	2005	676	1950	1287	666	42,1	10,4

kcal/h = 0,86 x Watt


Sistemi di fissaggio a parete

Wall fastening systems
Systèmes d'installation murale
Sistemas de fijación a la pared




Dimensioni corpo scaldante

Radiator body dimensions
Dimensions du corps chauffant
Dimensiones del cuerpo calefactor



Misure in mm: A=altezza B=larghezza C=interasse
Measures in mm: A=height B=width C=interaxis
Mesures in mm: A=hauteur B=largeur C=entraxe
Medidas in mm: A=altura B=ancho C=entre eje



note tecniche

Temperatura max di esercizio: 90 °C
Maximum operating temperature: 90 °C
Température maximum de fonctionnement: 90 °C
Temperatura máx de funcionamiento: 90 °C

Pressione max di esercizio: 400 kPa
Maximum operating pressure: 400 kPa
Pression maximum de fonctionnement: 400 kPa
Presión máx de funcionamiento: 400 kPa



Il corpo radiante è sempre in acciaio
The wall heater is always steel
Le radiateur est en acier toujours
El radiador es siempre de acero

Per impianto monotubo consultare note tecniche di dettaglio Pag.149
For single pipe installation, please consult technical notes Pag.151
Pour installation monotube consulter les renseignements techniques détaillés Pag.153
Para instalaciones monotubo consulte las informaciones técnicas detalladas Pag.155



dati tecnici

plate verticale doppio

Ref.	A	B	C	White & Colors		Peso	Cap.	
				$\Delta t=50^{\circ}\text{C}$	$\Delta t=30^{\circ}\text{C}$			
				W	W			
450 altezza height hauteur altura	PL2V045038	455	380	400	271	142	9,6	2,4
	PL2V045052	455	528	400	379	197	13,4	3,4
	PL2V045067	455	676	400	487	252	17,2	4,3
	PL2V045089	455	894	400	650	336	23,0	5,8
600 altezza height hauteur altura	PL2V060038	605	380	550	361	189	13,1	4,1
	PL2V060052	605	528	550	505	263	18,3	5,7
	PL2V060067	605	676	550	650	336	23,6	7,4
	PL2V060089	605	894	550	866	448	31,3	9,8
900 altezza height hauteur altura	PL2V090038	905	380	850	518	271	19,2	5,7
	PL2V090052	905	528	850	725	377	26,9	8,0
	PL2V090067	905	676	850	932	482	34,5	10,3
	PL2V090089	905	894	850	1243	643	46,0	13,7
1800 altezza height hauteur altura	PL2V180038	1805	380	1750	993	519	37,6	10,6
	PL2V180052	1805	528	1750	1390	723	52,6	14,8
	PL2V180067	1805	676	1750	1787	925	67,6	19,0
2000 altezza height hauteur altura	PL2V200038	2005	380	1950	1097	574	41,7	11,6
	PL2V200052	2005	528	1950	1536	799	58,3	16,2
	PL2V200067	2005	676	1950	1975	1022	75,0	20,9


$$\text{kcal/h} = 0,86 \times \text{Watt}$$

Sistemi di fissaggio a parete

Wall fastening systems

Systèmes d'installation murale

Sistemas de fijación a la pared





Dimensioni corpo scaldante

Radiator body dimensions

Dimensions du corps chauffant

Dimensiones del cuerpo calefactor



Misure in mm: A=altezza B=larghezza C=interasse
 Measures in mm: A=height B=width C=interaxis
 Mesures in mm: A=hauteur B=largeur C=entraxe
 Medidas in mm: A=altura B=ancho C=entre eje

note tecniche

Temperatura max di esercizio: 90 °C

Maximum operating temperature: 90 °C

Température maximum de fonctionnement: 90 °C

Temperatura máx de funcionamiento: 90 °C

Pressione max di esercizio: 400 kPa

Maximum operating pressure: 400 kPa

Pression maximum de fonctionnement: 400 kPa

Presión máx de funcionamiento: 400 kPa

Il corpo radiante è sempre in acciaio

The wall heater is always steel

Le radiateur est en acier toujours

El radiador es siempre de acero

Per impianto monotubo consultare note tecniche di dettaglio Pag.149

For single pipe installation, please consult technical notes Pag.151

Pour installation monotube consulter les renseignements techniques détaillés Pag.153

Para instalaciones monotubo consulte las informaciones técnicas detalladas Pag.155

